OPERATING MANUAL





ROTARY EVAPORATOR

REV11-150D



INDEX

1.Safety Instructions	. 2
2.Proper Use	. 4
3. Inspection	. 5
3.1 Receiving Inspection	5
3.2 Listing of Items	5
4.Control	. 6
4.1 Control elements	6
4.2 Display	9
5.Installation and Operation	. 10
5.1 Installation	10
5.2 Operation	14
6.Faults	. 15
7. Maintenance and Cleaning	. 16
8. Specifications	. 17

1.Safety Instructions

- Read the operating instructions in full before starting up and follow the safety instructions.
- Keep the operating instructions in a place where they can be accessed by everyone.
- Ensure that only trained staff work with the appliance.
- Follow the safety instructions, guidelines, occupational health and safety and accident prevention regulations. When working under a vacuum in particular!

• Wear your personal protective equipment in accordance with the hazard category of the medium to be processed. Otherwise there is a risk of:

- splashing liquids
- body parts, hair, clothing and jewelry getting caught
- injury as a result of glass breakage
- CAUTION! Inhalation of or contact with media such as poisonous liquids, gases, spray mist, vapors, dusts or biological and microbiological materials can be hazardous to user.
- Set up the device in a spacious area on an even, stable, clean, non-slip, dry and fireproof surface.

• Ensure that there is sufficient space above the device as the glass assembly may exceed the height of the device.

• Prior to each use, always check the device, accessories and especially the glass parts for damage. Do not use damaged components.

- Ensure that the glass assembly is tension-free! Danger of cracking as a result of:
- stress due to incorrect assembly,
- external mechanical hazards,
- local temperature peaks.
- Ensure that the stand does not start to move due to vibrations respectively unbalance.
- Beware of hazards due to:
- flammable materials
- combustible media with a low boiling temperature
- glass breakage
- CAUTION! Only process and heat up media that has a flash point higher than the adjusted safe temperature limit of the heating bath that has been set.

• The safe temperature limit of the heating bath must always be set to at least 25°C lower than the fire point of the media used.

• Do not operate the appliance in explosive atmospheres, with hazardous substances or under water.

• Only process media that will not react dangerously to the extra energy produced through processing.

This also applies to any extra energy produced in other ways, e.g. through light irradiation.

- Tasks with the device must only be performed when operation is monitored.
- Operation with excess pressure is not permitted (for cooling water pressure see "Technical Data").
- Do not cover the ventilation slots of the device in order to ensure adequate cooling of the drive.

• There may be electrostatic discharges between the medium and the drive which could pose a direct danger.

- The appliance is not suitable for manual operation.
- Safe operation is only guaranteed with the accessories described in the "Accessories" chapter.
- Refer to the operating instructions for the accessories, e.g. vacuum pump.
- Only use the device under an all side-closed exhaust, or a comparable protective device.

• Adapt the quantity and the type of distill and to the size of the distillation equipment. The cooler must work properly. Monitor the coolant flow rate at the cooler outlet.

• The glass equipment must always be ventilated when working under normal pressure (e.g. open outlet

at cooler) in order to prevent a pressure build-up.

• Please note that dangerous concentrations of gases, vapors or particulate matter can escape through the outlet at the cooler. Take appropriate action to avoid this risk, for example, downstream cold traps, gas wash bottles or an effective extraction system.

• Evacuated glass vessels must not be heated on one side; the evaporating flask must rotate during the heating phase.

• The glassware is designed for operation under a vacuum of up to 10 mbar. The equipment must be evacuated prior to heating (see chapter "Commissioning"). The equipment must only be aired again after cooling. When carrying out vacuum distillation, uncondensed vapors must be condensed out or safely dissipated. If there is a risk that the distillation residue could disintegrate in the presence of oxygen, only inert gas must be admitted for stress relief.

• CAUTION! Avoid peroxide formation. Organic peroxides can accumulate in distillation and exhaust residues and explode while decomposing!

• Keep liquids that tend to form organic peroxides away from light, in particular from UV rays and check them prior to distillation and exhaust for the presence of peroxides. Any existing peroxides must be eliminated. Many organic compounds are prone to the formation of peroxides e.g. dekalin, diethyl ether, dioxane, tetrahydrofuran, as well as unsaturated hydrocarbons, such as tetralin, diene, cumene and aldehydes, ketones and solutions of these substances.

• DANGER OF BURNING! The heating bath, tempering medium, evaporator piston and glass assembly can become hot during operation and remain so for a long time afterwards! Let the components cool off before continuing work with the device.

• ATTENTION! Avoid delayed boiling! Never heat the evaporating flask in the heating bath without switching on the rotary drive! Sudden foaming or exhaust gases indicate that flask content is beginning to decompose. Switch off heating immediately. Use the lifting mechanism to lift the evaporator piston out of the heating bath. Evacuate the danger zone and warn those in the surrounding area!

• When the device is switched off or the power supply disconnected, the internal safety lift removes the evaporator piston from the heating bath.

• CAUTION! Never operate the device when the evaporator piston is rotating and the lift is raised. Always lower the evaporator piston into the heating bath first before starting the rotation drive. Otherwise hot tempering medium may be sprayed out!

• Set the speed of the drive so no tempering medium is sprayed out as a result of the evaporator piston rotating in the heating bath. If necessary, reduce the speed.

• Do not touch rotating parts during operation.

• Imbalance may result in uncontrolled resonance behavior of the device or assembly. Glass apparatus may be damaged or destroyed. In the event of unbalance or unusual noises, switch off the appliance immediately or reduce the speed.

• The appliance does not start up again automatically following a cut in the power supply.

• The device is only disconnected from the power supply network if the device power switch is off or the plug is pulled out.

- The socket for the mains cord must be easily accessible.
- The voltage stated on the type plate must correspond to the mains voltage.
- Socket must be earthed (protective ground contact).

• Removable parts must be refitted to the appliance to prevent the infiltration of foreign objects, liquids etc.

• Protect the appliance and accessories from bumps and impacts.

• The appliance may only be opened by experts.

2.Proper Use

The instrument is designed for distilling in schools, laboratories or factories. Together with the accessories recommended by manufacturer, the device is suitable for:

- quick and gentle distillation of liquids
- evaporation of solutions and suspensions
- crystallization, synthesis or cleaning of fine chemicals
- drying of powder and granulate material
- recycling of solvents

This device is not suitable for using in residential areas or other constraints mentioned in Safety Instructions.

3. Inspection

3.1 Receiving Inspection

Unpack the equipment carefully and check for any damages which may have arisen during transport. Please contact manufacturer/supplier for technical support.



If there is any apparent damage to the system, please do not plug it into the power line. Loosen transportation lock before Power ON.

3.2 Listing of Items

The package includes the following items:

Items	Qt y
Main unit	1
Heating bath	1
Power cable	1
Glassware vertical	1
User Manual	1

Table 1

4.Control

4.1 Control elements



Figure 1











Items	Descriptions
Speed key "Speed"	Push the key and then rotate control knob to set the rated speed in the range from 20 to 280.
Temperature key "Temp"	Push the key and then rotate control knob to set the rated temperature in the range from room temperature to 180°C. Push the key for a long time , the screen displays "H20" as water bath mode, and the screen displays "01L" as oil bath mode.
Timer key "Timer"	Push the key and then rotate control knob to set the rated time in the range from 1 to 999min.
Int key "Int"	Push the key and then rotate control knob to set the interval for right-left running in the range from 1 to 999s.

Control knob	Clockwise rotate to increase program values. Rotate anti-clockwise to decrease program values. Press the knob, switch ON/OFF the unit.
Lift-up key	Press the key, the lift goes up. Release the key the lift stops and remains in that position.
Lift-down key	Press the key, the lift goes down. Release the key the lift stops and remains in that position.

Table 2

4.2 Display



Figure 5

Characters	Description	
Romote	Display in case of remote control.	
Mot	Display when the rotating function is switched ON	
Temp	Display when the heating function is switched ON.	
Timer	Display when timer function is switched ON.	
Int	Display when "Int" function is switched ON.	
Speed display area	When setting speed, displaying the setting value and flashed. The setting value does not flash until real speed reaches the set point.	
Speed symbol	Display when the rotating function is switched ON.	

Temperature display area	a When setting temperature, displaying the setting value. When the heating function is switched ON, displaying the real value.	
Temperature	Display when the heating function is switched ON.	
Timer display areaWhen setting timer, displaying the rated time. When the timer fu switched ON, displaying remaining time.		
Interval display area	Displaying the "Int" target value.	

Table 3

5.Installation and Operation

5.1 Installation

Adjustable base (Figure 6).



Figure 6

CAUTION! Loosen transportation lock (Figure 7).

• Hold the lift with your hand on the height position and remove the thumb screw on the back of the appliance (a).

• Once the transportation lock has been removed, the lift moves slowly to its upper end position. The distance is 150mm.

- Connect the device to the power supply using power cable (b).
- Connect the heating bath to the device (c)



• Remove the clamping device for the angle setting of the rotation drive on the right side of the lift by rotating the knurled screw (d) counterclockwise.

• Set the drive at an angle of approx.30° (Figure 8)

• Then secure the rotation drive from being accidentally turned by tightening the knurled screw in a clockwise direction.



Figure 8

• Open the locking device on the drive head by turning it 60° counter clockwise (e), (Figure 9). Feed the steam pipe in until it stops.

- Then lock the locking device by turning it clockwise by 60°.
- The plastic screw nut (f) helps loosen tight-fitting piston ground-in connections (Figure 9).

- Hold the tight-fitting evaporator piston and counterclockwise (e), and then turn the plastic screw nut (f) until the evaporator piston neck.



Note: Prior to commissioning, hand-tighten the plastic screw nut (f) left-aligned.

• Installing condenser seal (Figure 10 and Figure 11).







Figure 11

- Installing condenser (g) (Figure 12 and Figure 13).
- Load the cap nut (h) and locking spring (i) to condenser in turn.

- Tighten the cap nut hand-screwed (h). Start the device at 200 rpm for 2 min. Then tighten the cap nut









• Installing the vertical glassware condenser locking device (Figure 14). Use the transportation screw on the back of the appliance (a)



• Connecting tubes (Figure 15).





5.2 Operation

- Make sure the required operating voltage and power supply voltage match.
- Ensure the socket must be properly grounded.
- Plug in the power cable, ensure the power is on and begin initializing.
- Press Lift-up/Lift-down key, the lift goes up/down. Release Lift-up/Lift-down key, the lift stops.
- Push the speed key and then rotate control knob to set the rated speed.
- Push the temperature key and then rotate control knob to set the rated temperature.
- Push the timer key and then rotate control knob to set the rated time.
- Deactivate the timer by setting the target value to "0".
- Press the Int key and then rotate control knob to set the rated interval value.

- Deactivate the interval by setting the target value to"0".
- Press the control knob, switch ON.

• If these operations above are normal, the device is ready to operate. If not, the device may be damaged during transportation and please contact manufacturer/supplier.



Please don't remove the evaporating flask and receiving flask while the instrument is in operation.

6.Faults

- Instruments can't be power ON
- Check whether the power line is unplugged
- Check whether the fuse is broken or loose
- Fault in power on self-test
- Switch OFF the unit, then switch ON and reset the instruments to factory default setting.
- ERR 003, lift operation timeout
- Load overweight
- ERR 005, lift can't work
- Check whether the transportation lock is loose
- Load overweight

If these faults are not resolved, please contact manufacturer/supplier

7. Maintenance and Cleaning

Operate and maintain the product properly, so that it is in a good working state, which can extend the service life of the product. In routine service, keep the product dry and clean, remove the spilled liquid quickly, clean the outer surface with a non-grinding cleaner, and do not connect the power supply until all surfaces are dry. If liquid or moist solid enters the product, please disconnect the power supply quickly and leave off, and contact the manufacturer / supplier for more advice.

- Keep the product clean, and the cleaning solution is not allowed to flow into the machine.
- Power must be disconnected before maintenance and cleaning, and please use our recommended methods to clean the product. The method to clean:

Dye	Isopropanol
Building materials	Aqueous solution / isopropanol with active agent
Cosmetic	Aqueous solution / isopropanol with active agent
Food	Aqueous solution with active agent
Fuel oil	Aqueous solution with active agent

• You can consult the manufacturer about the materials that are not listed in the above table. Before using other cleaning methods, the user must confirm with the manufacturer / supplier that the method will not damage the instrument. When cleaning the product, please wear suitable protective gloves.

8. Specifications

Item	Specifications
Voltage [VAC]	100-240
Frequency [Hz]	50/60
Power [W]	1400
Motor	External rotor brushless motor
Speed Range [rpm]	20-280
Speed Display	LCD
Reversible Direction of Rotation	Yes
Temperature range [°C]	RT -180
Heat Control Accuracy[°C]	±1
Temperature Display	LCD
Heat Output[W]	1300
Lift	Motor
Stroke[mm]	150
Timer[mm]	1-999
Overall Dimensions [DxWxH, mm]	564x457x583
Weight [kg]	15
Permissible Ambient Temperature [°C]	5-40
Permissible Relative Humidity	80%
Protection class acc. to DIN 60529	IP20
USB	Yes

Table 4



Labstac LLC 82 Wendell Avenue, STE 100, Pittsfield, MA, 01201, USA Email: contact@labstac.com | Website: labstac.com